

Evaluation of High Efficiency Mist Eliminators

Paxton Giffin, Michael Parsons, Donna Rogers, and
Charles Waggoner

Institute for Clean Energy Technology

32nd Nuclear Air Cleaning Conference

Denver, CO

June 19, 2012

Project Oversight


Technical Working Group Membership

- John Dick – BNI
- Ryan Wilson -- BNI
- Jaimini Dave -- BNI
- Eric Slaathaug - BNI
- Joni Weamer - BNI
- John Shultz – DOE EM-21,
- Werner Bergman– Aerosol Science

Design Characteristics



A



B

HEME Project Test Matrix

Run Number	HEME ID Number	HEME Manufacturer	Media Velocity (ft/min)	Test Flow Rate (scfm)
AMCO-1	AMCO-1	AMISTCO	10	59
CECO-1	CECO-1	CECO Environmental	10	59
MECS-1	MECS-1	Monsanto	10	59
AMCO-2	AMCO-2	AMISTCO	15	88
CECO-2	CECO-2	CECO Environmental	15	88
MECS-2	MECS-2	Monsanto	15	88
AMCO-3	AMCO-3	AMISTCO	25	147
CECO-3	CECO-3	CECO Environmental	25	147
*MECS-3	MECS-3	Monsanto	15	88

Test Stand Capabilities



Volumetric Flow Rate	0.7 to 7.1 m ³ /min	25 to 250 cfm
Relative Humidity	50 to 99+%	
Filter Differential Pressure	0 to 7.5 kPa	0 – 30" w.c.
Mass Loading Rate (Dry)	200 to 600 mg/m ³	



Simulant Used for Aerosols




Component	Chemical Formula	Concentration (g/L)	Amount (g) Required to Make 200 L	Total (g)
Sodium Oxalate	$\text{Na}^2\text{C}_2\text{O}_2$	1.9	380	380
Aluminum Nitrate	$\text{Al}(\text{NO}_3)_3 \cdot 9\text{H}_2\text{O}$	78	15600	15600
Sodium Phosphate	$\text{Na}_3\text{PO}_4 \cdot 12\text{H}_2\text{O}$	25	5000	5500
Sodium Sulfate	Na_2SO_4	25	5000	5000
Sodium Nitrate	NaNO_3	104	20800	20800
Sodium Hydroxide	NaOH	127	25400	25400
Sodium Nitrite	NaNO_2	35	7000	7000
Sodium Carbonate	Na_2CO_3	58.57	11714	11714
Alumina	$\text{Al}(\text{OH})_3$			29000
Fe(III)				9600
Anti-Foaming Agent				80

Large & Small Aerosol Generation





Humid Conditions





Test Protocol


- Collect Initial Dry FEs
- Hydrate HEME
- Collect Initial Wet FEs
- Load to Intermediate dP
- Collect Intermediate FEs
- Hydrate HEME
- Repeat Intermediate Step 2x
- Collect Final FEs



Typical Test Data


HEME Differential Pressure and Differential Temperature vs. Time

Run ID: HEME-AMCO-1
Flow Rate: 2.49 m³/min





A

Condition Stability
Run ID: HEME-AMCO-1
Flow Rate: 2.49 m³/min



B

Wet Aerosol Measurement



Typical HEME Test Results


As Received Mass	66.7 lb
Dried (Tare) Mass	66.7 lb
Final Wet Mass	76.2 lb
Final Dry Mass	68.3 lb
Total Dry Mass Loading	1.6 lb
Average FE for DOP	98.67%
Average FE for Dry Surrogate	96.4%
FE for >50 nm DOP	99.78%
FE for Particles >50 nm Dry Surrogate	99.31%
Wet Mass Concentration (Filter Method)	2012.26 mg/m ₃
Wet Mass Concentration (Impinger Method)	2009.70 mg/m ₃
Dry Mass Concentration (Filter Method)	392.83 mg/m ₃
Dry Mass Concentration (Impinger Method)	578.22 mg/m ³

Upstream PSD, Downstream PSD, FE

Run ID: HEME-AMCO-1

Flow Rate: 88CFM

Challenge: Surrogate




Filtering Efficiency vs. Time


Run ID: HEME-AMCO-1

Flow Rate: 88CFM

Challenge: DOP



HEME Filtering Efficiency versus Testing Flow Rate



Moisture on Tube Sheet



Wicking Through Medium



HEME Filtering Efficiencies

		Filtering Efficiency (%)			
		DOP		Surrogate	
Filter ID :	Flow Rate	All Diameters	Diameters > 50 nm	All Diameters	Diameters > 50 nm
AMCO-1	88 cfm	98.7	99.8	96.4	99.31
AMCO-2	147 cfm	93	96.8	90.3	95.6
AMCO-3	59 cfm	96.4	99.8	92	98.4
CECO-1	88 cfm	98.3	99.8	96.9	99.2
CECO-2	147 cfm	97.4	98.8	93	97.8
CECO-3	59 cfm	98.9	99.3	98.1	99.1
MECS-1	88 cfm	98.8	99.8	95.7	99.1
MECS-2	147 cfm	92.8	99.5	81	92.3

Mass Loading and Times

	Loading Times (hr)		
Filter Manufacturer:	59 cfm	88 cfm	147 cfm
AMCO	6.88	6.06	4.81
CECO	8.08	6.68	5.47
MECS	N/A	2.23	2.56

	Mass Gained		
Filter Manufacturer:	59 cfm	88 cfm	147 cfm
AMCO	0.9	1.6	1.5
CECO	1.3	1.5	1.2
MECS	N/A	0.7	0.6

Nozzle 2


Arrangement and Spray Patterns






08.04.2011

Test Stand Modification



HEME Annulus Post Wash Test



Annular Spray-Wash Test Results

Spray Nozzle 1

Initial Dry Mass	59.7lb
Initial Dry dP	4.12 in. w.c.
Initial Dry FE (> 50 nm)	99.91%
Initial Wet dP	4.27 in. w.c.
Initial Wet FE (> 50 nm)	99.93%
Spray Number 1 Time	5 min
Spray Number 1 Pressure	30 PSI
Spray Number 1 Total Volume	7.4 GPM @ 15 Psi
Post Spray dP	14 in. w.c. @ 40 CFM
Post Spray dP after drying with fan for 8 hrs	6.7 in. w.c. @ 88 CFM
Mass After 8 hrs Air Drying w/ max 15 in. w.c. dP	85.1 lb
Mass after oven drying 90C for 9 hrs and 120C for 8 hrs	74.3 lb
Mass after last drying for 5 hrs at 140C	70.0 lb
Final Dry dP	4.5 in. w.c.
Final Dry FE (> 50 nm)	99.80%
Final Wet dP	4.87 in. w.c.
Final Wet FE (> 50 nm)	99.81%

Spray Nozzle 2

Initial Dry Mass	70.0 lb
Initial Dry dP	4.5 in. w.c.
Initial Dry FE (> 50 nm)	99.80%
Initial Wet dP	4.87 in. w.c.
Initial Wet FE (> 50 nm)	99.81%
Spray Number 1 Time	30 sec
Spray Number 1 Pressure	10 psi
Spray Number 1 Total Volume	1.42 gal
Post Spray 1 dP	6.75 in. w.c. @ 88 CFM
Spray Number 2 Time	2 min
Spray Number 2 Pressure	10 psi
Spray Number 2 Total Volume	5.68 gal
Post Spray 2 dP after drip dry for 15 hrs	11 in. w.c. @ 88 CFM
Post Spray 2 dP after drying with fan for 5 Hrs	7.75 in. w.c.
Intermediate FE Before Drying	99.60%
Mass Before Drying	92.1 lb
Mass after Oven Drying	59.6 lb
Final Dry dP	3.99
Final Dry FE (> 50 nm)	99.45
Final Wet dP	4.35

Acknowledgement

This work was conducted under funding provided by DOE, Contract Number DEFC0106EW07040 06040310